

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0981:112

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Greenheck Fan Corp., 400 Ross Ave., Schofield WI 54476-0410
Contact: Marty Gissel (715) 355-6611 Fax (715) 355-3954

DESIGN: Models FSDR5 and SSFSDR5 round single blade fire dampers. Refer to listee's data sheet for additional detailed product description and operational considerations.

| | Diameter, In. | | | | |
|----------------|-------------------|----------------|----------------|---------------------|--------------|
| RATING: | <u>Models</u> | <u>Minimum</u> | <u>Maximum</u> | <u>Installation</u> | <u>Rated</u> |
| | FSDR5 and SSFSDR5 | 6 | 24 | V or H | 1 1/4 Hr |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical and horizontal installation.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use as described under "Design" and "Installation".

NOTE: Refer to Listing No. 3230-0981:113 for leakage rated dampers.

12-22-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager